



INTÉRIOR FINISH
 FURRING 1"X3" HOR. 16" c/c
 GYPSUM 1/2" MIN.

FRAMING STUD 2" X 6" @ 16" C/C
 VAPOR BARRIER

INSULATION
 SILL GASKET

VAPOR BARRIER

SILL GASKET

ANCHOR BOLT AT 4' C/C
 1/2" X 8" LG.

STABILISATION TIES

POLYCRETE
 BIG BLOCK 6" MASONRY

REINFORCING STEEL
 HORIZONTAL AND VERTICAL
 AS PER CODES
 AND REGULATIONS
 OR BY STRUCTURAL ENGINEER

INTÉRIOR FINISH
 FURRING 1"X3" VER. 16" c/c
 GYPSUM 1/2" MIN.

POLYCRETE BIG BLOCK 1600-10"
 REGULAR 24" X 96"

4" (100mm) CONCRETE SLAB
 WIREMESH OR
 STRUCTURAL FIBER
 2 1/2" (64) INSULATION PANEL

CONTINUOUS CONCRETE FOOTING
 20 mPa - 14 mm AGGREGATES
 REINFORCING STEEL:
 3 CONTINUOUS 10M
 15M TRANSVERSAL 16" C/C
 DOWEL L 15M STAGGERED 16" C/C

MASONRY VENEER

SHEATING

MASONRY CONNECTOR
 AS PER CODES
 AND REGULATIONS

AIR BARRIER
 OR EQUIVALENT

INSULATION

MASONRY CONNECTOR
 AS PER CODES
 AND REGULATIONS

WATERPROOF MEMBRANE
 OR EQUIVALENT

IMP: MECHANICALLY FIXING THE TOP

FLASHING MATERIAL
 AND WEEP HOLES, AS PER CODES
 AND REGULATIONS

POLYCRETE
 BIG BLOCK 10" MASONRY

ACRYLIQUE PARGING
 OR EQUIVALENT

BACKFILL SOIL
 SLOPE OF 2% MIN.

WATERPROOF MEMBRANE
 OR EQUIVALENT

NOTE: Sheathing 7/16" (optional)
 as a membrane protection

GEOTEXTILE MEMBRANE

CRUSHED STONE 3/4"

PERFORATED DRAIN



TITLE:
 Big Block 1600-10" masonry, + Big Block 6" masonry,
 for modular home or other.

DRAWING NO:
 BB-10-06-S2005-EN

DATE
 2012-05-28

DISCLAIMER NOTICE

SPECIFIC INFORMATION REQUIRED FOR COMPLIANCE WITH
 LOCAL CODES IS THE RESPONSABILITY OF THE DESIGNER.

DRAWING BY:

REV. NO:

REV. DATE: